

CERTIFICATE OF ANALYSIS

Work Order : **EW1903821**
Client : **MERRY BEACH CARAVAN PARK**
Contact : David Jansen
Address : Merry Beach Rd
 Kioloa NSW 2539

Telephone : ----
Project : Merry Beach Monitoring
Order number : P0501061
C-O-C number : ----
Sampler : Peter Young
Site : Merry Beach
Quote number : WO/010/16
No. of samples received : 3
No. of samples analysed : 3

Page : 1 of 3
Laboratory : Environmental Division NSW South Coast
Contact : Glenn Davies
Address : 1/19 Ralph Black Dr, North Wollongong 2500
 4/13 Geary Pl, North Nowra 2541
 Australia NSW Australia
Telephone : +61 2 4225 3125
Date Samples Received : 03-Sep-2019 16:49
Date Analysis Commenced : 04-Sep-2019
Issue Date : 17-Sep-2019 09:50



Accreditation No. 825
 Accredited for compliance with
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Alexis Bell	Environmental Service Representative	Administration - Wollongong, NSW
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Tony DeSouza	Senior Microbiologist	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- Oil and Grease analysis was conducted by ALS Canberra under NATA accreditation number 992.
- MF = membrane filtration
- CFU = colony forming unit
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 - 100cfu.
- MW006 is ALS's internal code and is equivalent to AS4276.7.
- O&G (W-TOG_LL) is conducted by ALS Canberra NATA accreditation no. 992, site no. 1524.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)		Client sample ID		884/Eff1	884/Eff2	Influent	----	----
Client sampling date / time				03-Sep-2019 09:40	03-Sep-2019 09:50	03-Sep-2019 10:10	----	----
Compound	CAS Number	LOR	Unit	EW1903821-001	EW1903821-002	EW1903821-003	-----	-----
				Result	Result	Result	----	----
EA005P: pH by PC Titrator								
pH Value	----	0.01	pH Unit	8.07	8.15	7.96	----	----
EA025: Suspended Solids								
Suspended Solids (SS)	----	5	mg/L	6	9	----	----	----
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)	----	5	mg/L	----	----	3080	----	----
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	0.25	----	4.68	----	----
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Nitrite + Nitrate as N	----	0.01	mg/L	12.2	----	4.76	----	----
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser								
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	2.8	----	223	----	----
EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser								
^ Total Nitrogen as N	----	0.1	mg/L	15.0	----	228	----	----
EK067G: Total Phosphorus as P by Discrete Analyser								
Total Phosphorus as P	----	0.01	mg/L	2.60	----	100	----	----
EP030: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand	----	2	mg/L	<2	----	313	----	----
MW006: Faecal Coliforms & E.coli by MF								
Faecal Coliforms	----	1	CFU/100mL	<1	----	1700000	----	----
<i>Escherichia coli</i>	----	1	CFU/100mL	----	2200	1700000	----	----
Subcontracted Analysis								
Oil and Grease	----	1	mg/L	<1	----	<1	----	----